



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: April 7, 2017
Client: Eastern Christian Schools
Address: 50 Oakwood Ave
North Haledon, NJ 07508

Project: High School

Sample description: Drinking Water / 1st Draw / DWS5057-1
Sample location: Field Blank
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:48
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	01:04	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-2
Sample location: Caf Kitchen HS KC 1
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:49
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	01:10	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-3
Sample location: Caf Kitchen HS FP 2
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:51
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.44 µg/L	15 µg/L	04/01/17	01:16	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-4
Sample location: Hall by 311/313 HS WC 3R
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:52
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	01:28	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-5
Sample location: Hall by 311/313 HS WC 4L
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:53
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	01:52	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-6
Sample location: By Closet 409 WS WC 5
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:55
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	01:58	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-7
Sample location: Media Center HS KC 6
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:57
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.43 µg/L	15 µg/L	04/01/17	02:16	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-8
Sample location: 300 Hall by 301 HS WC 7
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 08:59
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:22	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-9
Sample location: Room 211 HS TL 8
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:02
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.00 µg/L	15 µg/L	04/01/17	02:28	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-10
Sample location: Room 211 HS WC 9
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:03
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:34	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-11
Sample location: Main Entrance HS WC 10
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:04
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:40	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-12
Sample location: Gym04 B Locker HS WC 11
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:05
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:46	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-13
Sample location: Gym03 G Locker HS WC 12
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:06
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:52	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS5057-14
Sample location: Gym 05 HS IM 13
Sampled by: D. Diaz
Sample date: 03/28/17
Time: 09:07
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	04/01/17	02:58	1	2 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen
 Susan Van Veen, Lab Manager
 NJ Laboratory Certification ID # 14013

Date April 7, 2017