



**Environmental and Laboratory Services**  
90 ½ West Blackwell St., Dover, New Jersey 07801  
(973) 989-0010 P, (973) 989-0156 F

## Analytical Results

**Date:** April 7, 2017  
**Client:** Eastern Christian Schools  
**Address:** 50 Oakwood Ave  
North Haledon, NJ 07508  
**Project:** Middle School

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-1  
**Sample location:** Field Blank  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:26  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/31/17	22:51	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-2  
**Sample location:** Front Lobby MS WC 1R  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:27  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/31/17	23:15	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-3  
**Sample location:** Front Lobby MS WC 2L  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:28  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/31/17	23:21	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-4  
**Sample location:** Kitchen Room 100 MS FP 3  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:30  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.91 µg/L	15 µg/L	03/31/17	23:39	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-5  
**Sample location:** Nurse Room 205B MS NS 4  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:35  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.42 µg/L	15 µg/L	03/31/17	23:46	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-6  
**Sample location:** Nurse Room 205B MS NS 5  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:36  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	11.9 µg/L	15 µg/L	03/31/17	23:52	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-7  
**Sample location:** Hall by Room 204 MS WC 6  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:38  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.21 µg/L	15 µg/L	03/31/17	23:58	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-8  
**Sample location:** 204 Staff Room MS TL 7  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:39  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.74 µg/L	15 µg/L	04/01/17	00:04	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-9  
**Sample location:** Hall by 217 MS WC 8L  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:40  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.13 µg/L	15 µg/L	04/01/17	00:09	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-10  
**Sample location:** Hall by 217 MS WC 9R  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:41  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.57 µg/L	15 µg/L	04/01/17	00:15	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-11  
**Sample location:** Hall by 303 MS WC 10L  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:43  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	< 2 µg/L	15 µg/L	04/01/17	00:21	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-12  
**Sample location:** Hall by 303 MS WC 11 R  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:44  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	< 2 µg/L	15 µg/L	04/01/17	00:28	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-13  
**Sample location:** Hall by 306 MS WC 12L  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:45  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	< 2 µg/L	15 µg/L	04/01/17	00:34	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-14  
**Sample location:** Hall by 306 MS WC 13R  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:46  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	< 2 µg/L	15 µg/L	04/01/17	00:46	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-15  
**Sample location:** Girls Locker Room MS DW 14  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:50  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	10.6 µg/L	15 µg/L	04/01/17	00:52	1	2 µg/L

**Sample description:** Drinking Water / 1<sup>st</sup> Draw / DWS5055-16  
**Sample location:** Boys Locker Room MS DW 15  
**Sampled by:** D. Diaz  
**Sample date:** 03/28/17  
**Time:** 09:52  
**Analyst:** B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.05 µg/L	15 µg/L	04/01/17	00:58	1	2 µg/L

$\mu\text{g/L}$  = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Yang (For SV)  
Susan VanVeen, Lab Manager  
NJ Laboratory Certification ID # 14013

April 10, 2017  
Date